



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07732		


SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/20/23 - 13:30	TEMP OF SAMPLE UPON RECEIPT: 21° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY	ANALYTE	SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID		LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07732	Lead	157	7/19/23	14:02	7/27/23	12:51	SM3113B-93	15 µg/L	<2.0 µg/L
23-07733	Lead	158	7/19/23	14:02	7/27/23	13:09	SM3113B-93	15 µg/L	<2.0 µg/L
23-07734	Lead	150A	7/19/23	14:04	7/27/23	13:15	SM3113B-93	15 µg/L	<2.0 µg/L
23-07735	Lead	NW Gym	7/19/23	14:04	7/27/23	13:20	SM3113B-93	15 µg/L	<2.0 µg/L
23-07736	Lead	NE Gym	7/19/23	14:05	7/27/23	13:26	SM3113B-93	15 µg/L	<2.0 µg/L
23-07737	Lead	2nd Floor Left Bathroom	7/19/23	14:10	7/27/23	13:32	SM3113B-93	15 µg/L	3.77 µg/L
23-07738	Lead	Kitchen 3 Sink	7/19/23	14:12	7/27/23	13:38	SM3113B-93	15 µg/L	<2.0 µg/L
23-07739	Lead	Kitchen Hand Sink	7/19/23	14:12	7/27/23	13:44	SM3113B-93	15 µg/L	<2.0 µg/L
23-07740	Lead	Kitchen Produce Sink	7/19/23	14:13	7/27/23	13:50	SM3113B-93	15 µg/L	<2.0 µg/L
23-07741	Lead	1st Floor Staff Lounge Sink	7/19/23	14:15	7/27/23	13:56	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY: 
Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07732		


SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/20/23 - 13:30	TEMP OF SAMPLE UPON RECEIPT: 21° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07742	Lead	Health Office Eye Wash Sink	7/19/23	14:16	7/27/23	14:14	SM3113B-93	15 µg/L	<2.0 µg/L
23-07743	Lead	Health Office Bathroom	7/19/23	14:16	7/27/23	14:32	SM3113B-93	15 µg/L	<2.0 µg/L
23-07744	Lead	Rm 127 Workroom Bathroom	7/19/23	14:17	7/27/23	14:39	SM3113B-93	15 µg/L	2.11 µg/L
23-07745	Lead	105 Girls Bathroom Left	7/19/23	14:20	7/27/23	14:45	SM3113B-93	15 µg/L	<2.0 µg/L
23-07746	Lead	105 Girls Bathroom Right	7/19/23	14:20	7/27/23	14:51	SM3113B-93	15 µg/L	<2.0 µg/L
23-07747	Lead	105 to 106 Bubbler	7/19/23	14:21	7/27/23	14:57	SM3113B-93	15 µg/L	<2.0 µg/L
23-07748	Lead	106 Boys Bathroom Left	7/19/23	14:21	7/27/23	15:03	SM3113B-93	15 µg/L	<2.0 µg/L
23-07749	Lead	106 Boys Bathroom Right	7/19/23	14:23	7/27/23	15:09	SM3113B-93	15 µg/L	<2.0 µg/L
23-07750	Lead	107 Bubbler	7/19/23	14:26	7/27/23	15:15	SM3113B-93	15 µg/L	3.76 µg/L
23-07751	Lead	107 Sink	7/19/23	14:26	7/27/23	15:21	SM3113B-93	15 µg/L	3.05 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY: 
Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07732		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/20/23 - 13:30	TEMP OF SAMPLE UPON RECEIPT: 21° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY		ANALYTE			SAMPLE COLLECTION		SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID		LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT		
23-07752	Lead	108 Bubbler	7/19/23	14:27	8/1/23	12:08	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07753	Lead	108 Sink	7/19/23	14:28	8/1/23	12:14	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07754	Lead	109 Bubbler	7/19/23	14:34	8/1/23	12:20	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07755	Lead	109 Sink	7/19/23	14:34	8/1/23	12:26	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07756	Lead	110 Bubbler	7/19/23	14:35	8/1/23	13:50	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07757	Lead	110 Sink	7/19/23	14:35	8/1/23	12:32	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07758	Lead	110 Left Bathroom	7/19/23	14:36	8/1/23	12:38	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07759	Lead	110 Right Bathroom	7/19/23	14:37	8/1/23	12:44	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07760	Lead	101 Bubbler	7/19/23	14:43	8/1/23	13:03	SM3113B-93	15 µg/L	<2.0 µg/L		
23-07761	Lead	101 Sink	7/19/23	14:43	8/1/23	13:20	SM3113B-93	15 µg/L	<2.0 µg/L		

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07732		


SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/20/23 - 13:30	TEMP OF SAMPLE UPON RECEIPT: 21° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07762	Lead	101 Left Bathroom	7/19/23	14:43	8/1/23	13:26	SM3113B-93	15 µg/L	<2.0 µg/L
23-07763	Lead	101 Right Bathroom	7/19/23	14:43	8/1/23	13:33	SM3113B-93	15 µg/L	<2.0 µg/L
23-07764	Lead	102 Bubbler	7/19/23	14:45	8/1/23	13:38	SM3113B-93	15 µg/L	<2.0 µg/L
23-07765	Lead	102 Sink	7/19/23	14:45	8/1/23	13:44	SM3113B-93	15 µg/L	<2.0 µg/L
23-07766	Lead	103 Bubbler	7/19/23	14:46	8/1/23	13:56	SM3113B-93	15 µg/L	<2.0 µg/L
23-07767	Lead	103 Sink	7/19/23	14:46	8/1/23	14:02	SM3113B-93	15 µg/L	<2.0 µg/L
23-07768	Lead	104 Bubbler	7/19/23	14:47	8/1/23	14:08	SM3113B-93	15 µg/L	4.76 µg/L
23-07769	Lead	104 Sink	7/19/23	14:47	8/1/23	14:26	SM3113B-93	15 µg/L	<2.0 µg/L
23-07772	Lead	Cafeteria Bubbler	7/19/23	14:52	8/1/23	14:44	SM3113B-93	15 µg/L	<2.0 µg/L
23-07773	Lead	Science Hallway Bubbler	7/19/23	14:57	8/1/23	14:51	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY: 
Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07732		


SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/20/23 - 13:30	TEMP OF SAMPLE UPON RECEIPT: 21° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY	ANALYTE	SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID		LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07774	Lead	Art NE Sink	7/19/23	14:57	8/1/23	14:57	SM3113B-93	15 µg/L	<2.0 µg/L
23-07775	Lead	Art NW Sink	7/19/23	14:57	8/1/23	15:03	SM3113B-93	15 µg/L	<2.0 µg/L
23-07776	Lead	Science Lab Prep Sink	7/19/23	14:58	8/1/23	15:09	SM3113B-93	15 µg/L	<2.0 µg/L
23-07777	Lead	Bubbler by 235	7/19/23	15:02	8/1/23	15:15	SM3113B-93	15 µg/L	<2.0 µg/L
23-07778	Lead	231 Sink	7/19/23	15:13	8/1/23	15:21	SM3113B-93	15 µg/L	<2.0 µg/L
23-07779	Lead	201 Bubbler	7/19/23	15:38	8/1/23	15:27	SM3113B-93	15 µg/L	<2.0 µg/L
23-07780	Lead	201 Sink	7/19/23	15:38	8/1/23	15:33	SM3113B-93	15 µg/L	<2.0 µg/L
23-07781	Lead	201 Girls Bathroom Left	7/19/23	15:37	8/3/23	10:33	SM3113B-93	15 µg/L	2.31 µg/L
23-07782	Lead	201 Girls Bathroom Right	7/19/23	15:37	8/3/23	10:39	SM3113B-93	15 µg/L	<2.0 µg/L
23-07783	Lead	202 Bubbler	7/19/23	15:38	8/3/23	10:45	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY: 
Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07732		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/20/23 - 13:30	TEMP OF SAMPLE UPON RECEIPT: 21° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07784	Lead	202 Sink	7/19/23	15:38	8/3/23	10:51	SM3113B-93	15 µg/L	<2.0 µg/L
23-07785	Lead	203 Bubblers	7/19/23	15:40	8/3/23	10:57	SM3113B-93	15 µg/L	4.48 µg/L
23-07786	Lead	203 Sink	7/19/23	15:40	8/3/23	11:18	SM3113B-93	15 µg/L	30.6 µg/L
23-07787	Lead	204 Bubblers	7/19/23	15:41	8/3/23	11:42	SM3113B-93	15 µg/L	<2.0 µg/L
23-07788	Lead	204 Sink	7/19/23	15:41	8/3/23	11:48	SM3113B-93	15 µg/L	3.27 µg/L
23-07789	Lead	205 Bubblers	7/19/23	15:43	8/3/23	11:54	SM3113B-93	15 µg/L	<2.0 µg/L
23-07790	Lead	205 Sink	7/19/23	15:43	8/3/23	12:00	SM3113B-93	15 µg/L	<2.0 µg/L
23-07791	Lead	205 Girls Bathroom Left	7/19/23	15:44	8/3/23	12:06	SM3113B-93	15 µg/L	<2.0 µg/L
23-07792	Lead	205 Girls Bathroom Right	7/19/23	15:44	8/3/23	12:12	SM3113B-93	15 µg/L	2.49 µg/L
23-07793	Lead	206 Boys Bathroom Left	7/19/23	15:45	8/3/23	12:18	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07732		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/20/23 - 13:30	TEMP OF SAMPLE UPON RECEIPT: 21° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY	ANALYTE	SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID		LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07794	Lead	206 Boys Bathroom Right	7/19/23	15:45	8/3/23	12:24	SM3113B-93	15 µg/L	<2.0 µg/L
23-07795	Lead	206 Bubbler	7/19/23	15:46	8/3/23	12:30	SM3113B-93	15 µg/L	<2.0 µg/L
23-07796	Lead	206 Sink	7/19/23	15:46	8/3/23	13:25	SM3113B-93	15 µg/L	<2.0 µg/L
23-07809	Lead	Handicap Bathroom by 110	7/19/23	14:37	8/8/23	12:32	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07797		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/25/23 - 11:55	TEMP OF SAMPLE UPON RECEIPT: 26° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07797	Lead	207 Bubblers	7/24/23	15:18	8/3/23	13:43	SM3113B-93	15 µg/L	<2.0 µg/L
23-07798	Lead	207 Sink	7/24/23	15:18	8/3/23	13:49	SM3113B-93	15 µg/L	<2.0 µg/L
23-07799	Lead	208 Bubblers	7/24/23	15:18	8/3/23	13:55	SM3113B-93	15 µg/L	<2.0 µg/L
23-07800	Lead	208 Sink	7/24/23	15:18	8/3/23	14:01	SM3113B-93	15 µg/L	<2.0 µg/L
23-07801	Lead	209 Bubblers	7/24/23	15:20	8/3/23	14:07	SM3113B-93	15 µg/L	<2.0 µg/L
23-07802	Lead	209 Sink	7/24/23	15:20	8/3/23	14:13	SM3113B-93	15 µg/L	2.39 µg/L
23-07803	Lead	209 Boys Bathroom Left	7/24/23	15:22	8/3/23	14:19	SM3113B-93	15 µg/L	<2.0 µg/L
23-07804	Lead	209 Boys Bathroom Right	7/24/23	15:22	8/3/23	14:25	SM3113B-93	15 µg/L	2.82 µg/L
23-07805	Lead	211 Staff Lounge Sink	7/24/23	15:24	8/3/23	14:31	SM3113B-93	15 µg/L	<2.0 µg/L
23-07806	Lead	210 Bubblers	7/24/23	15:25	8/8/23	12:14	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 8/8/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-07797		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 7/25/23 - 11:55	TEMP OF SAMPLE UPON RECEIPT: 26° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------

LABORATORY	ANALYTE	SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID		LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-07807	Lead	210 Sink	7/24/23	15:25	8/8/23	12:20	SM3113B-93	15 µg/L	<2.0 µg/L
23-07808	Lead	3rd Floor Bubbler by 303	7/24/23	15:27	8/8/23	12:26	SM3113B-93	15 µg/L	<2.0 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.