



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
tcwaterclinic@gmail.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 9/1/23	CLIENT/CLIENT ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413	SCHOOL/ADDRESS Yinghua Academy 1616 Buchanan St NE Minneapolis, MN 55413
REPORT #: 23-09357		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 8/31/23 - 13:32	TEMP OF SAMPLE UPON RECEIPT: 22° C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---------------------------------------	---------------------------------------	--

LABORATORY	ANALYTE	SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID		LOCATION	DATE	TIME	DATE	TIME	METHOD	MCL	RESULT
23-09357	Lead	203 Sink - Instant Flush	8/28/23	10:00	9/1/23	11:07	SM3113B-93	15 µg/L	67.7 µg/L
23-09358	Lead	203 Sink - 5 Minute Flush	8/28/23	10:11	9/1/23	11:13	SM3113B-93	15 µg/L	<2.0 µg/L
23-09359	Lead	203 Bubbler - Instant Flush	8/28/23	10:15	9/1/23	11:19	SM3113B-93	15 µg/L	4.65 µg/L
23-09360	Lead	203 Bubbler - 5 Minute Flush	8/28/23	10:20	9/1/23	11:25	SM3113B-93	15 µg/L	3.18 µg/L

*The analyte(s) reported for the above listed sample(s) pass if the result is at or below the MCL (maximum contaminant level) and fail if the result is above the MCL. The MCL is set by the U.S. EPA and followed by the Minnesota Department of Health for safe drinking water.

NOTES

APPROVED BY:

Bill VanArsdale - Lab Manager

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.